

Double concentration test

4395 series

Protect Dosing test analysis kit.

Analysis in seconds to determine the required dosage.

Rapid colorimetric test to verify the correct presence of Spray Protect 1 or Protective 100 liquid is present in the air conditioning circuit water. Suitable for the correct completion of the system logbook when the system is first start-up of the system and for subsequent periodic checks. Complete package including case, instruction sheet, 20 ml test tube, 2 15 ml bottles of reagent and one 25 ml bottle of control liquid or 25 ml. The package allows for approximately 25 tests to be performed.

The pack includes:

- case
- instruction sheet
- 20 ml test tube
- 2 x 15 ml bottles of reagent
- 1 x 25 ml bottle of control liquid

Code	Pack	Cat.
43950002	1	20.04

